



DEPARTMENT OF GENERAL SERVICES
CHRISTOPHER L. WINSTEAD P.E.
DIRECTOR

THE COMPLETE ADDENDUM 1 WILL BE MAILED TO PLAN HOLDERS. ADDENDUM NO. 1

TO: Prospective Bidders and Others Concerned
FROM: County of Henrico/URS Corporation
DATE: February 1, 2012
RE: IFB # 11-9178-1CE
Name of Project: Three Chopt High Pressure Zone Improvements

The following changes, corrections, deletions, clarifications, and/or additions constitute Addendum No.1. Please acknowledge receipt of this Addendum No.1, dated February 1, 2012 on the Bid Form when returning your Bid package. **Failure to acknowledge this addendum may result in your bid being declared non-responsive.** All other general terms, conditions and specifications shall remain the same.

Project Manual:

1. Page 00020-1 **REPLACE** the fourth paragraph to the following:

To qualify, all bids shall be submitted using the Bid Form furnished by the Department of Public Utilities, a copy of which is bound in the Project Manual; incomplete or segregated bids will not be accepted. Work included in this contract shall be substantially completed within 210 calendar days from the date of the Notice to Proceed, and it shall be completed and ready for final payment within 240 calendar days from the date of the Notice to Proceed.

2. Page 00300-3 Section 6a **REPLACE** the section with the following:

BIDDER agrees that the Work shall be substantially complete within 210 calendar days and completed and ready for final payment in accordance with Paragraph 14.13 of the General Conditions within 240 calendar days, after the commencement of Contract Times as defined in the General Conditions.

3. Page 00500-2 Section 3.1 **REPLACE** the section with the following:

The Work shall be substantially completed within 210 calendar days from the date the Contract Time commences as provided in paragraph 2.3 of the General Conditions, and it shall be completed and ready for final payment in accordance with paragraph 14.13 of the General Conditions within 240 calendar days from the date the Contract Time commences.

Drawings:

1. **Question:** Will the COUNTY locate, uncover, and close all valves shown on sheet G-4.

Response: The COUNTY will locate, uncover, and exercise all valves that need to be closed. It is the responsibility of the Contractor to coordinate with the COUNTY and make certain that all the valves which are required to be closed are identified and closed when the new Three Chopt High Pressure Zone is scheduled to go on-line.

2. **Question:** Who is the Contractor for the new Three Chopt High Pressure Zone Pumping Station upgrade and when will he complete his work. Will the County coordinate start-up activities with the pumping station?

Response: TA Loving is the Three Chopt WPS contractor. Per the contract substantial completion is scheduled for 5/2/2012. The COUNTY will coordinate start-up activities with the new Three Chopt High Pressure Zone Pumping Station.


3. **Question:** There are several short sections of waterline being installed. Will the County require all of them to be tested?

Response: All waterlines will be tested in accordance with the Contract Documents.

4. **Change:** On Sheet C-18 of the Drawings **REPLACE** the detail for "Pavement Replacement for Pipe Trench" with the attached "Pavement Replacement for Pipe Trench" detail.

DIRECTOR OF GENERAL SERVICES
CHRISTOPHER WINSTEAD, P.E.

COUNTY OF HENRICO, VIRGINIA
GENERAL SERVICES/PURCHASING
CAROLYN L. EFFORD, CPPB
PROCUREMENT SUPERVISOR
(804) 501-5688
eff@co.henrico.va.us



SKETCH SHOWING PAVEMENT PATCH FOR SINGLE ISOLATED CUTS

SKETCH SHOWING PAVEMENT OVERLAY FOR LONGITUDINAL OR MULTIPLE CUTS

NOTES:

1. THIS DETAIL IS TO BE USED IN ALL LOCATIONS WHERE PROPOSED STORM SEWER OR UTILITY CROSSES EXISTING PAVEMENT.
2. OVERLAYS IN SHOULDER SECTIONS MUST BE WEDGED DOWN TO EXISTING SHOULDERS AT A 1":1' GRADE WITH MATERIAL MATCHING EXISTING CONDITIONS.
3. IN CURB AND GUTTER SECTIONS, MILLING IS REQUIRED PRIOR TO PLACEMENT OF THE OVERLAY.
4. TEMPORARY OR PERMANENT ASPHALT MUST BE PLACED IN ROADWAY TRENCHES BY THE CLOSE OF EACH WORKDAY.



PAVEMENT REPLACEMENT FOR PIPE TRENCH

County of Henrico
Department of Public Works

JANUARY 1, 2002

PVTREPLA.DWG